



**New Hampshire Department of Health and Human Services  
Chiller Routine Inspections and Preventative Maintenance  
#RFP-2018-NHH-02-CHILL**

---

## **ADDENDUM #2**

On February 10, 2017, the New Hampshire Department of Health and Human Services published a request for applications, requesting applications from vendors who are qualified for Chiller Routine Inspections and Preventative Maintenance.

The Department is publishing this addendum to:

**1. Delete and replace Appendix D, Section 2.1.32, with the following:**

Clean condenser.

**2. Delete and replace Appendix D, Section 2.1.33, with the following:**

Clean and brush condenser tubes.

**3. Delete Appendix D, Section 2.3.2.**

**4. Add Appendix D, Section 2.6:**

The Contractor shall perform Eddy Current Testing on evaporators and condensers to determine baseline of both chillers for future comparison.